

Edward Deyermond, Mayor Edward J. Gregory, Trustee Brian Gilbride, Trustee Sandra L. Schroeder, Village Clerk

**CUSTOMER** 

631-725-0222 P.O. Box 660 55 Main St., Sag Harbor, L.I., N.Y. 11963-0015 Fax: 631-725-0316 OFFICE OF THE FIRE MARSHAL 631-725-2804 Gregory N. Ferraris, Deputy Mayor Tiffany Scarlato, Trustee Craig Furrer, Village Treasurer Lisa Kombrink, Esq.

## **COMMERCIAL KITCHEN HOOD FIRE SYSTEM REPORT**

**CONTRACTOR** 

| NAME                 |               |  |  |  |            |   | NAME      |          |          |   |  |  |  |
|----------------------|---------------|--|--|--|------------|---|-----------|----------|----------|---|--|--|--|
| ADDRESS              |               |  |  |  |            | AD  | DRESS     |          |          |   |  |  |  |
| PHONE                |               |  |  |  |            | CITY/STA  | ATE/ZIP   |          |          |   |  |  |  |
| OWNER/MANAGER        |               |  |  |  |            | 1   | PHONE     |          |          |   |  |  |  |
|                      |               |  |  |  |            |   |           |          |          |   |  |  |  |
| EXTINGUISHING SYSTEM |               |  |  |  | INSPECTION |   |           |          |          |   |  |  |  |
| MANUFACTURER         |               |  |  |  |            | TODAY'S DATE  COMPANY THAT PERFORMED  SAME AS ABOVE UNK |           |          |          |   |  |  |  |
| MODEL NUMBER         | · <del></del> |  |  |  |            |   | LAST      | NSPECTIO | <b>'</b> |   |  |  |  |
| TYPE                 |               |  |  |  |            | DATE (  | OF LAST I | NSPECTIO | N        |   |  |  |  |
| CYLINDER SIZE        |               |  |  |  |            |   |           |          |          |   |  |  |  |
|                      |               |  |  |  |            |   |           |          |          |   |  |  |  |
|                      |               |  |  |  |            |   |           |          |          |   |  |  |  |
|                      |               |  |  |  |            |   |           |          |          |   |  |  |  |
|                      |               |  |  |  |            |   |           |          |          |   |  |  |  |
|                      |               |  |  |  |            |   |           |          |          |   |  |  |  |
|                      |               |  |  |  |            |   |           |          |          | 4 |  |  |  |
|                      |               |  |  |  |            |   |           | <u> </u> |          |   |  |  |  |

DIAGRAM OF INSTALLED EQUIPMENT

OVER >

| SYSTEM SUPERVISION  |  | EXHAUST HOOD   |                            |  |  |  |  |  |  |
|---|--|--|----------------------------|--|--|--|--|--|--|
| IS THERE A FIRE ALARM SYSTEM PRESENT?   | ☐YES ☐ NO ☐ UNK  | HOOD CLEANING STICKER IS AFFIXED                               | ☐YES ☐NO                   |  |  |  |  |  |  |
| IS THE EXTINGUISHING SYSTEM MONITORED BY THE FIRE ALARM?  | □YES □ NO □ N/A □ UNK                                  | DATE OF LAST HOOD CLEANING                                     | DATE                       |  |  |  |  |  |  |
| ELECTRICITY IS REQUIRED FOR EXTINGUISHING SYSTEM OPERATION  | □YES □ NO  | GREASE ACCUMULATION  | ☐ HEAVY ☐ MODERATE ☐ LIGHT |  |  |  |  |  |  |
| SYSTEM HAS AUDIBLE OR VISUAL<br>ALERT AFTER DISCHARGE   | □YES □ NO  | FILTERS ARE INTACT   | ☐YES ☐NO                   |  |  |  |  |  |  |
| MANUAL ACTIVATION   | -  | FAN IS IN OPERATING ORDER                                      | ☐YES ☐NO ☐ UNK             |  |  |  |  |  |  |
| LOCATED BETWEEN 42 IN. AND 60 IN.<br>ABOVE THE FLOOR  | □YES □ NO  | LIGHTING IN HOOD IS PROPERLY PROTECTED FROM DAMAGE             | ☐YES ☐NO ☐ N/A ☐UNK        |  |  |  |  |  |  |
| ACCESSIBLE AND LOCATED IN A PATH OF EGRESS  | □YES □ NO  | COOKING EQUIPMENT  |                            |  |  |  |  |  |  |
| CLEARLY IDENTIFIES THE HAZARD PROTECTED   | □YES □ NO  | 16" SEPARATION BETWEEN FRIER AND SURFACE FLAME EQUIPMENT       | ☐YES ☐NO ☐ N/A ☐UNK        |  |  |  |  |  |  |
| FAILURE WILL IMPAIR AUTOMATIC<br>SYSTEM OPERATION   | □YES □ NO □ UNK  | BARRIER INSTALLED BETWEEN FRIER<br>AND SURFACE FLAME EQUIPMENT | ☐ YES ☐ NO ☐ N/A ☐ UNK     |  |  |  |  |  |  |
| SEAL IS INTACT  | □YES □NO EQUIPMENT APPEARS TO BE IN OPERABLE CONDITION |  | ☐YES ☐NO ☐ UNK             |  |  |  |  |  |  |
| PERSONNEL INSTRUCTED IN THE USE OF THE SYSTEM   | □YES □NO   | COMBUSTIBLES STORED NEAR<br>COOKING EQUIPMENT                  | ☐YES ☐NO                   |  |  |  |  |  |  |
| AUTOMATIC OPERATION   | N .  | EXTINGUISHING SYSTEM   |                            |  |  |  |  |  |  |
| VERIFIED TRAVEL OF CABLE AND LINK POSITION  | ☐YES ☐ NO ☐ N/A  | COMPLIANT COVERAGE FOR ALL APPLIANCES                          | ☐YES ☐NO                   |  |  |  |  |  |  |
| VERIFIED OPERATION OF GAS<br>SHUTOFF VALVE  | □YES □ NO □ N/A  | COMPLIANT COVERAGE OF EXHAUST<br>DUCT AND PLENUM AREAS         | □YES □NO                   |  |  |  |  |  |  |
| VERIFIED OPERATION OF MICRO-<br>SWITCH  | □YES □ NO □ N/A  | CARTRIDGE WEIGHT CHECKED                                       | ☐YES ☐ NO ☐ N/A            |  |  |  |  |  |  |
| CHECKED AND CLEANED FUSIBLE LINKS   | □YES □ NO □ N/A  | PIPING AND CYLINDER SECURELY FASTENED TO STRUCTURE             | □YES □NO                   |  |  |  |  |  |  |
| MANUFACTURE DATE OF FUSIBLE LINKS   | DATE:  | CYLINDER HYDROSTATIC TEST DATE                                 | DATE:                      |  |  |  |  |  |  |
| REPLACED FUSIBLE LINKS  | □YES □ NO □ N/A  | AUXILIARY EQUIPMENT  |                            |  |  |  |  |  |  |
| NOZZLES CLEANED   | □YES □ NO □ N/A  | TYPE K PORTABLE FIRE EXTINGUISHER PRESENT                      | ☐YES ☐NO                   |  |  |  |  |  |  |
| PROPER NOZZLE CAPS IN PLACE   | □YES □ NO □ N/A  | EXTINGUISHER IS PLACARDED AS BACKUP EXTINGUISHMENT MEANS       | ☐YES ☐NO                   |  |  |  |  |  |  |
| GAS SHUTOFF VALVE CONTROLS ALL EQUIPMENT PROTECTED BY SYSTEM  | □YES □ NO □ N/A  | PERSONNEL ARE INSTRUCTED IN THE USE OF EXTINGUISHER            | ☐YES ☐NO                   |  |  |  |  |  |  |
| LEAVE NO QUESTION UNANSWERED  COMMENTS:   |  |  |                            |  |  |  |  |  |  |
|   |  |  |                            |  |  |  |  |  |  |
| HAS ANY EQUIPMENT BEEN ADDED SINCE LAST INSPECTION?    YES  NO  UNK   SEXTINGUISHING SYSTEM UL 300 COMPLIANT?   YES  NO |  |  |                            |  |  |  |  |  |  |
| SIGNED:   |  |  |                            |  |  |  |  |  |  |
| SIGNED: TECHNICIAN NAME NOT COMPANY NAME OWNER OR AGE   |  |  |                            |  |  |  |  |  |  |
| RETURN TO THE SAG HARROR VILLAGE FIRE MARSHAL   |  |  |                            |  |  |  |  |  |  |

RETURN TO THE SAG HARBOR VILLAGE FIRE MARSHAL PO BOX 660, SAG HARBOR, N.Y. 11963 TEL: 631-725-2804 FAX: 631-725-4852